avisaro
industrial information technology

Avisaro 4.0 Product Series

# Quick Guide

# 4..20mA or 0..10V

# Bus Data Logger & Gateway

# ‘4.0 Shell’

( “M48xx7” / “C48xx7” / “G48xx7” )

Version / Date: 2024/06/25

# 1 TABLE OF CONTENT

2 This document ..... 5
2.1 History of changes ..... 5
2.2 Audience ..... 5
2.3 Location ..... 5
2.4 Language Versions ..... 5
2.5 Other documents and Resources ..... 5
2.6 Active Links ..... 5
2.7 Document creation ..... 5
2.8 Imprint and contact ..... 6
3 Enclosure and User Controls ..... 7
3.1 Start and stop operation ..... 7
3.2 LED Blink-Codes ..... 7
3.3 Real-Time Clock ..... 7
3.4 Enclosure “4.0 Shell” ..... 8
3.4.1 Opening “Shell” enclosure ..... 9
4 USB Storage Stick ..... 10
4.1 Filesystem and Storage size ..... 10
4.2 Formatting ..... 10
4.3 Choosing the right memory stick ..... 10
4.4 Recommended Memory Sticks ..... 11
4.4.1 Recommended ..... 11
4.4.2 Not recommended ..... 12
5 Interface description and Pin Layout ..... 13
5.1 Micro-USB Client ..... 13
5.2 Power Supply ..... 13
5.2.1 Power M8 Connector ..... 13
5.3 Analog 0..10V Interface ..... 14
5.3.1 Default 0..10V settings ..... 14
5.3.2 Example: Wiring “single ended” measurement ..... 14
5.3.3 Example: Wiring “differential” measurement ..... 15

5.4 Analog 4..20mA current loop interface ..... 16
5.4.1 Default 20mA settings ..... 16
5.4.2 2-wire and 3-wire setup considerations ..... 16
5.4.3 2x/4x “Shell” M8-Connector ( “M48887”, “C48887”, “G48887” ) ..... 16
6 Configuration: ‘PC Companion Software’ ..... 19
6.1 How to configure Avisaro “Series 4.0” products ..... 19
6.2 Concept of operation ..... 19
6.3 Detailed documentation ..... 19
6.4 “PC Companion Software” Installation ..... 20
6.5 Driver installation ..... 20
6.6 Initial Set-Up ..... 21
6.7 Using the PC Companion Tool ..... 21
6.8 Global Hardware Setup ..... 22
6.8.1 Global HW settings ⇨ System functions ..... 22
6.8.2 Global HW settings ⇨ Networking ..... 22
6.8.3 Global HW settings ⇨ Interfaces (Digital) ..... 22
6.8.4 Global HW settings ⇨ Interfaces (Analog) ..... 22
6.8.5 Global HW settings ⇨ Sensors ..... 23
6.9 Interfaces ⇨ 4..20mA / 0..10V ..... 23
6.9.1 Sample Rate ..... 23
6.9.2 Stream to ..... 23
6.9.3 Graphic display ..... 23
6.10 Data Processing ⇨ 4..20mA / 0..10V ..... 24
6.10.1 Storage Format ..... 24
6.10.2 Storage endpoint ..... 25
6.10.3 Network endpoint ..... 25
6.11 Data Endpoints ⇨ USB Stick ..... 26
6.11.1 “Create new file” policy ..... 26
6.12 Data Endpoints ⇨ Network endpoint ..... 27
6.12.1 Data Endpoints ⇨ Network endpoint ⇨ Protocol ..... 28
6.13 Data Endpoints ⇨ Cloud Settings ..... 29
6.13.1 Data Endpoints ⇨ Cloud Settings ⇨ Mode ..... 30
6.13.2 Data Endpoints ⇨ Remote firmware update ..... 30

7 Firmware and Configuration Update ..... 32
7.1 Configuration Update ..... 32
7.1.1 Introduction ..... 32
7.1.2 Via “PC Companion” Software ..... 32
7.1.3 Via USB Stick ..... 32
7.2 Firmware Update ..... 33
7.2.1 Introduction ..... 33
7.2.2 Via USB stick ..... 34
7.2.3 Via “PC Companion” Software ..... 34
7.2.4 Via FTP server / internet ..... 34
8 Declarations ..... 36
8.1 EC/EU Declaration of Conformity ..... 36
9 Contact and Support ..... 37

# 2 THIS DOCUMENT

## 2.1 HISTORY OF CHANGES

The document version equals the document date in the format yyyy.mm.dd.

| Version | Description |
|---|---|
| 2024/06/09 | Update of pin layout |
| 2024/03/01 | Initial version |

## 2.2 AUDIENCE

The intended reader of this document are technical personnel installing, configuring, and using the Avisaro device.

## 2.3 LOCATION

Check for the latest document version the following link:

Link: https://www.avisaro.de/files/Avisaro/40_Docu/M48xx7-C48xx7-G48xx7.pdf

## 2.4 LANGUAGE VERSIONS

This document is available in English language only.

## 2.5 OTHER DOCUMENTS AND RESOURCES

Other documents and resources can be found in the support area of our website:

English: https://shop.avisaro.com/en/info/support.html

German: https://shop.avisaro.com/de/info/support.html

## 2.6 ACTIVE LINKS

This PDF contains active links. By 'clicking', e.g., in the table of contents, you can get to the appropriate paragraph or by 'clicking' on the "Go to:" in the header you can get back.

## 2.7 DOCUMENT CREATION

This document was created using the “Avisaro Document Builder”. Single text blocks are merged into targeted documents. Thus, text blocks can be reused in several places, yet no need to update them manually when changes occur.

We point this out because:
Advantage is that compact and targeted documents are available. The disadvantage is that on rare occasions, a paragraph might have comments which do not fit 100% in the place it is used.

## 2.8 IMPRINT AND CONTACT

This document is provided by:

Avisaro AG
Grosser Kolonnenweg 18 E
30163 Hannover
Germany

Web: www.avisaro.com

Email: info@avisaro.com

# 3 ENCLOSURE AND USER CONTROLS

## 3.1 START AND STOP OPERATION

The Avisaro 4.0 starts with operation right after power on if an USB stick is inserted. Also, after re-inserting a USB stick, the operation starts automatically.

## 3.2 LED BLINK-CODES

There is one multicolor LED to signal states of the Avisaro device.

| **Code** | **What is means** | **Action** |
|---|---|---|
| Green & blue fading | All is fine<br>Idle state, no data arriving | None |
| Green flashing | Data are coming in<br>(RS232, CAN interface)[1)] | None |
| Yello constant | All is fine, USB stick is checked after mounting | None |
| Red flashing | No USB stick<br>or button was pushed | Insert USB stick<br>Or press button again |
| Red (about 2sec) than blue (about 2sec) | Logger restarts.<br>This should not happen during normal operation | Check power supply |

[1)] On analog loggers (e.g., 4…20mA) and similar interfaces, data are read continuously, thus no green flashing is shown

## 3.3 REAL-TIME CLOCK

A battery buffered internal real time clock is available for time stamping data, start and stop network upload and other controls. The battery is a rechargeable “memo-buff” cell - specifically designed for RTC operations. During regular operation, the battery is recharged over a 48h period. During non-operating times (= supply power off), the date and time settings are maintained for several month.

If the Avisaro device is networked, a network time server (SNTP) can be used to set time and date automatically.

If an Avisaro GPS receiver is connected, the RTC can be set using satellite time.

It is possible to define time zones settings.

## 3.4 ENCLOSURE "4.0 SHELL"

Front with the 3x "M8" connector configuration. The enclosure is opened by opening the "snap lock" as shown here:

"4.0 Shell" version with PG cable gland:

"4.0 Shell" version with WAGO terminal

Opened enclosure with (optional) LTE device and USB stick (not included unless purchased):



For the M8 option, the interfaces are located as follow:

### 3.4.1 Opening “Shell” enclosure



# 4 USB STORAGE STICK

## 4.1 FILESYSTEM AND STORAGE SIZE

Commercially available USB 2.0 / 3.0 memory sticks can be used. It is recommended to exclude branded products - no "promotional items" with your own logo imprint.

There are no speed requirements. Memory sticks that are advertised as particularly fast offer no (!) advantage in the Avisaro data logger. Typically these optimizations are designed for cameras etc..

Memory sizes from 4 to 256 GByte are supported. As file system FAT or FAT32 (preferred) is used. NTSF or others are not supported.

Memory sticks are typically not in the scope of delivery - each application typically has different requirements.

## 4.2 FORMATTING

Usually, sticks come pre-formatted, so you don’t have to do anything. Even larger than 32GByte sticks are preformatted with FAT32.

Sticks equal or smaller than 32 GByte can be formatted with Windows Operating system as it is. Use “FAT32” as the desired format.

Windows Operating System does not allow to format sticks larger then 32 GByte with the FAT32 file system. Usually, sticks come pre-formatted, so you don’t have to do anything. If there is a need to reformat a stick, the Avisaro Device can be used. Please refer to later chapter “Configuration: PC Companion Software” .. “USB Storage” ether in this document, or in the overall “User Manual Serie 4.0” document.

Alternatively, third party tools for Windows can be used to format large USB sticks. Please note: Avisaro can not support those third party tools within our technical support via telephone or email.

## 4.3 CHOOSING THE RIGHT MEMORY STICK

For **industrial** use, special parameters may have to be observed:

The **temperature** range should be considered. There are "industrial grade" memory sticks available - often designed as "SLC" version - which are also suitable for harsh environments.

The **mechanical dimension** should also be considered. It is disadvantageous if the stick protrudes openly from the housing and could be knocked off. In this case short sticks are recommended. If the logger is installed protected, then a longer stick is easier to use.

The appropriate **memory size** also depends on the intended use. Due to the technology, memory sticks with an extremely high capacity are typically less robust than smaller memory sizes. The loggers have a "ring memory" that can be optionally activated. If the memory stick becomes full (approx. less than 100MB free memory) the oldest files are deleted - this is a useful setting for some applications.

## 4.4 Recommended Memory Sticks

It is difficult to recommend consumer grade USB sticks as detailed technical information are not published.

Nevertheless, we try (please check for updated documentation often, link found in previous chapters):

Last updated: April 5th, 2022

### 4.4.1 Recommended

| Manufacturer | Model | Picture | Capacity | Technology | Remarks |
|---|---|---|---|---|---|
| SanDisk | Ultra Fit | | 16 GB | Consumer | |
| SanDisk | Ultra | | 32 GB | Consumer | |
| Intenso | Slim Line | | 8 GB | Consumer | |
| Kingston | Data Traveler 2 | | 16 GB | Consumer | |

| | | | | | |
|---|---|---|---|---|---|
| Innodisk | USB Drive 3SE | | 4-32 GB | Industrial | SLC Technology |

### 4.4.2 Not recommended

| Manufacturer | Model | Picture | Capacity | Technology | Remarks |
|---|---|---|---|---|---|
| Verbatim | Slider<br>Store N Go | | 8 GB | Consumer | Stick failures after short period of time |

# 5 INTERFACE DESCRIPTION AND PIN LAYOUT

## 5.1 MICRO-USB CLIENT

The Micro-USB client interface is used for configuration only.

*USB in "4.0 Sky" products*

*USB Client in "4.0 Silver" products*



*USB Client in "4.0 Shell" products*

Most Avisaro devices are powered through the Micro-USB client port, however only for configuration. A stable regular operation is not guaranteed. Use the regular power supply for normal operation.

A "Micro USB" cable is used. As those cables are widely available, this cable is not part of the scope of delivery to avoid electronic waste.

**Heads-up:** There are sometimes Micro USB cable which only do power supply, but not data. Those are used i.e., with mobile phones. If the Avisaro device is powered, but no data connection to the PC – just choose a different USB cable.

## 5.2 POWER SUPPLY

For regular operation, an external power supply must be connected. Powering the device through micro-USB is not (!) sufficient.

### 5.2.1 Power M8 Connector

Power supply is used with a male plug:



| Connector | Interface | Pin | Signal | Direction |
|---|---|---|---|---|
| M8,<br>4 pol, male | Supply<br>Power | 1 | n/c<br>(for selected devices: Trigger In) | IN |
| | | 2 | GND | PWR |
| | | 3 | n/c | |
| | | 4 | 12V to 32V DC | PWR |

The matching plug are industry standard M8 4pol female connector. Examples:

- CONEC: SAL-8-RKC4-S5,5
- Binder: 99 3376 100 04

## 5.3 Analog 0..10V Interface

The 0..10V interface can be used for “simple” single-ended voltage measurements, as well as demanding “differential” measurements. The measuring is isolated - thus it can be operated on a different ground reference than the power supply.

### 5.3.1 Default 0..10V settings

To avoid sensor signal clipping, the voltage levels of analog channels must be kept within the range in reference to the isolated GND :

- negative Pin Voltage $\geqslant$ 0V referenced to isolated GND
- positive Pin Voltage $\leqslant$ 15V referenced to isolated GND

The input resistance is 1MOhm.

### 5.3.2 Example: Wiring “single ended” measurement

As the data logger allows for advanced differential measurements, single ended measuring needs to have all negative inputs wired to reference ground.




The signal side is isolated from the power side - thus signal ground can be different from supply ground.

### 5.3.3 Example: Wiring “differential” measurement

The data logger allows for true differential measurement. The following diagram illustrates the wiring.



## 5.4 ANALOG 4..20MA CURRENT LOOP INTERFACE

The analog 20mA interface is a differential current input with an internal resistance of 49.9 Ohms. This allows to interface industrial standard 4…20mA sensors to the data logger.

### 5.4.1 Default 20mA settings

Input resistor: 49.9 Ohm

Measurement range: 0 .. 20 mA

To avoid sensor signal clipping, the voltage levels of analog channels must be kept within the range:

negative Pin Voltage ≥ 0V

positive Pin Voltage ≤ 3V referenced to GND

### 5.4.2 2-wire and 3-wire setup considerations

- Use external power – the data logger does not provide current sourcing
- Tie "-" of the ADC channel to Signal Ground if 2 wire setup is used
- ADC channels are isolated

### 5.4.3 2x/4x "Shell" M8-Connector ( "M48887", "C48887", "G48887" )

Industry standard M8 connector (female) are used.

Using the DIP switches, the input/output ports are configured either as 4..20mA or 0..10V.



ON: 4..20mA , OFF: 0..10V

With the current firmware version 2.83 dated from 20th of June 2024, all switches either have to be ON or OFF. Thus, all ports are either 4..20mA or 0..10V. In future firmware releases,



**Configuration as 4..20mA interfaces: All DIP switches to ON**




| Connector | Interface | Pin | Signal | Direction |
|---|---|---|---|---|
| M8,<br>4 pol, female | 2x 0..20mA<br><br>Port A<br>Or<br>Port B | 1 | 1st 4..20mA (+) | IO |
| | | 2 | 1st 4..20mA (-) | IO |
| | | 3 | 2nd 4..20mA (-) | IO |
| | | 4 | 2nd 4..20mA (+) | IO |
| | | Shield | Signal Ground | GND |

Position of input ports in log-file:

```
2024/06/21,11:11:58,277, $20MA, Port-B 1st, Port-B 2nd, Port-A 1st, Port-A 2nd
```

Example output for 4..20mA:

```
2024/06/21,11:11:54,277, $20MA, 0.000 mA, 10.042 mA,-0.001 mA, 0.000 mA
2024/06/21,11:11:55,277, $20MA, 0.000 mA, 10.042 mA,-0.001 mA, 0.001 mA
```

```
2024/06/21,11:11:56,277, $20MA, 0.000 mA, 10.041 mA,-0.001 mA,-0.001 mA
2024/06/21,11:11:57,277, $20MA, 0.000 mA, 10.041 mA,-0.001 mA, 0.000 mA
```

**Configured as 0..10V interfaces: All DIP switches to OFF**




| Connector | Interface | Pin | Signal | Direction |
|---|---|---|---|---|
| M8,<br>4 pol, female | 2x 0..10V<br><br>Port A<br>Or<br>Port B | 1 | 1st 0..10V (+) | IO |
| | | 2 | 1st 0..10V (-) | IO |
| | | 3 | 2nd 0..10V (-) | IO |
| | | 4 | 2nd 0..10V (+) | IO |
| | | Shield | Signal Ground | GND |

Matching connectors are industry standard M8 4x pol connectors. Examples:

- CONEC SAL8 RSC4
- Binder 99 3383 00 04 Binder

# 6 CONFIGURATION: 'PC COMPANION SOFTWARE'

## 6.1 HOW TO CONFIGURE AVISARO "SERIES 4.0" PRODUCTS

The basic principle of how to configure the Avisaro "Series 4.0" products is:

1) Download and install the "Avisaro PC Companion Software".
2) Connect the Avisaro device via USB cable.
3) Choose the correct COM port and click on "connect".
4) The software presents all the settings you can make and guides you to avoid conflicting configurations.
5) Click on "save configuration" to store changes in the Avisaro device.
6) Reboot the Avisaro Device so that the new configuration takes effect.

Details are described further down in this document.

## 6.2 CONCEPT OF OPERATION

The Avisaro 4.0 is divided into sections:




Data are received through an "Interface" and then forwarded to the "Data Processing" section. All formatting happens here and then data is forwarded to the "Data Endpoint".

## 6.3 DETAILED DOCUMENTATION

This current document shows only selected parts of the full "Avisaro PC Companion Software" user manual. The motivation is to keep this document as compact as possible.

Please find the extensive "Avisaro PC Companion Software" document in the support section of the Avisaro website:

German: https://www.avisaro.de/de/40_Dokumentation.html

English: https://www.avisaro.com/en/40-ENG-Documentation.html

## 6.4 "PC COMPANION SOFTWARE" INSTALLATION

Download the latest version from:

German site: https://shop.avisaro.com/de/Z46330.html

English site: https://shop.avisaro.com/en/Z46330.html

Please check the section "DRAFT version" only if advised by Avisaro Support.

There are two version available:

- Install: this runs a Windows installer. You need admin rights to run.
- Direct: this contains a folder with all files. You can run the *.exe directly from there.

Windows warns the user before installing or using software downloaded from the Internet. So, if you click on "Avisaro_40_Companion_v2.56_Setup.exe", the warning will occur:




After a click on "More Info", the box shows:




Select "Run anyway" to continue.

## 6.5 DRIVER INSTALLATION

If you connect the Avisaro Device to the PC using a Micro USB cable, a virtual COM port driver is installed. If this driver does not install automatically, you can download and install this manually.

Scroll down in the same download sites as above to the headline "Serial Driver Software" (en) or "Serielle Treiber Software". Or, follow directly this link:

https://download.avisaro.com/files/Avisaro/40_PC_App/en.stsw-stm32102.zip

## 6.6 Initial Set-Up

After starting the companion software, the virtual COM port number needs to be entered. You can find this number in the Windows “Device Manager”.

This setting is stored for future use.

Click on ‘open COM port’ – which will turn green if successful. You can use the “check” button to verify that the connection is alive.

You can use the “Check” button to verify the connection to the Avisaro Device. It should light up green when clicked.

The baudrate setting for “if connected through real RS22.. “ can be ignored. This setting is used only in special projects and not scope of this document.




All settings are deactivated if there is no Avisaro Device attached.

## 6.7 Using the PC Companion Tool

Click on “Write Config” to transmit changes in the PC tool to the Avisaro device. Click on “Read Config” to display the currently stored values (if you navigate between options, the latest settings are read of course automatically).

Most settings become active only after reboot. This can be done in Commands ⇨ Device Control: Reboot Device.

## 6.8 GLOBAL HARDWARE SETUP

Hardware modules are enabled/disabled in this setting. Of course – only those interfaces who are physically there can be activated. Please check device serial number for details.

In most cases, devices are shipped with proper settings on this page.




### 6.8.1 Global HW settings ⇨ System functions

Don't touch those settings unless advised by technical support team from Avisaro.

### 6.8.2 Global HW settings ⇨ Networking

Activate the network interface which is physically present.

### 6.8.3 Global HW settings ⇨ Interfaces (Digital)

Activate the digital interface which is physically present.

### 6.8.4 Global HW settings ⇨ Interfaces (Analog)

Activate the analog interface which is physically present.

For the "4..20mA / 0..10V" Shell product (M48878, C48878, G4887), the analog interface can be configured by using the DIP switches.

Position of DIP Switch



All ON = 4..20mA




All OFF = 0..10V



### 6.8.5 Global HW settings ⇨ Sensors

Activate the sensor which is physically present.

## 6.9 INTERFACES ⇨ 4..20MA / 0..10V

The analog interfaces for 4..20mA and 0..10V are managed in the same settings page.




### 6.9.1 Sample Rate

Select the desired sample rate in samples per seconds (hz).

### 6.9.2 Stream to

In this point of time, only “Analog data (generic)” can be selected.

### 6.9.3 Graphic display

The graphic display shows the readings from the ports. This is designed to check the proper function during setup.

## 6.10 DATA PROCESSING ⇨ 4..20MA / 0..10V

Settings for collection 0..10V or 4..20mA analog data.




### 6.10.1 Storage Format




| Storage format ⇨ | | |
|---|---|---|
| | OFF | This is the default setting.<br>… |

| | |
|---|---|
| 4x Current (mA)(NMEA) |  <br>Storage format example with the setting above:<br>`2022/03/02,15:45:33,332, $20MA, 9.979 mA, 0.761 mA, 0.001 mA,-0.001 mA`<br>`2022/03/02,15:45:34,331, $20MA, 9.980 mA, 0.730 mA,-0.001 mA, 0.001 mA`<br>`2022/03/02,15:45:35,330, $20MA, 9.980 mA, 0.742 mA,-0.001 mA, 0.000 mA` |
| 2x Current (mA)(NMEA) | Storage format example with the setting:<br>`2022/03/02,16:41:24,795, $20MA, 6.924 mA,-0.501 mA`<br>`2022/03/02,16:41:25,795, $20MA, 6.874 mA,-0.461 mA`<br>`2022/03/02,16:41:26,795, $20MA, 6.882 mA,-0.452 mA` |

### 6.10.2 Storage endpoint

Fixed for now to „Generic file”

### 6.10.3 Network endpoint




| |
|---|
| Network endpoint ⇨ |

| | | |
|---|---|---|
| | OFF | No network forwarding |
| | Network (IP) | Data are forwarded to the “Network (IP)” endpoint<br>The same format is used as set in “Storage format” |

(PC companion version 2.65 and firmware version 2.65 or higher required)

## 6.11 DATA ENDPOINTS ⇨ USB STICK

The file handling is configured in this section. Depending on the application, choose when and how to create files.




### 6.11.1 “Create new file” policy

Description of “Create new file” policy selection.

“1st file” settings are relevant. A directory called “log_1” is created on the USB memory. All data are contained in this directory.

“2nd file" settings apply to customer specific applications only.



| “Create new file” ⇨ | | |
|---|---|---|
| | OFF | No log file is created, no data are logged |
| | one file | |
| | every hour | Every hour a new file<br>Log file name: yymmddhh.txt |
| | every hour with ringbuffer | Every hour a new file. If memory space is exceeded, the oldest file is deleted.<br>Log file name: yymmddhh.txt |
| | every day | Log file name: yyyymmdd.txt |
| | at new event (time) | |
| | at new event (keyword)(PDF) | |
| | every new start | |

## 6.12 Data Endpoints ⇨ Network endpoint

Data from a digital (RS232, CAN, ..) interface and some of the analog interfaces (0..10V, 4..20mA) can be streamed over the network.

Remember to active the “Forward data” option in the ‘data processing’ section.



### 6.12.1 Data Endpoints ⇨ Network endpoint ⇨ Protocol

Description of “General Settings”:




| Protocol ⇨ | |
|---|---|
| **OFF** | **This is the default setting.**<br>**No data is forwarded.** |
| UDP/IP | Data is send and received using the UDP/IP protocol<br>  <br>**Target IP:** data are sent to this IP. Use *.*.*.255 for subnet broadcasts<br>**Target port:** port data are sent to<br>**Local port:** port data are received (see “WiFi Setting” for this device IP address) |
| TCP/IP client | Data is send and received using the TCP/IP protocol. The Avisaro device is client – thus it is connecting to a server.<br>  <br>**Target IP:** data are sent to this IP address.<br>**Target port:** port data are sent to<br>**Local port:** not used |
| TCP/IP client | Data is send and received using the TCP/IP protocol. The Avisaro device is server – thus it is waiting for a client to connect to the Avisaro device. |

| | |
|---|---|
| |  <br>**Target IP:** ignore, not used<br>**Target port:** ignore, not used<br>**Local port:** port data are received (see "WiFi Setting" for this device IP address) |

## 6.13 Data Endpoints ⇨ Cloud Settings

The Cloud features of the Avisaro devices are best described in separate application specific documents. Thus, here the settings are described briefly without the 'large picture' behind it.



### 6.13.1 Data Endpoints ⇨ Cloud Settings ⇨ Mode

Description of “General Settings”:




| Mode ⇨ | | |
|---|---|---|
| | **OFF** | **This is the default setting.**<br>**No data are uploaded into the Cloud or FTP Server.** |
| | FTP Upload | Data stored are uploaded on an hourly base to the FTP server specified in the settings. |
| | MQTT Client | This feature is defined in customer specific projects only. |
| | Store & Collect | Stored data are made available to be picked up by a Server Software.<br>Parameter are:<br>• User and Password<br>• Device Name<br>Typically, “Store&Collect” goes along with the “Avisaro Dashboard Software” (see separate documentation) |

### 6.13.2 Data Endpoints ⇨ Remote firmware update

Check chapter “Firmware and Configuration Update” later in this document for details.



# 7 FIRMWARE AND CONFIGURATION UPDATE

## 7.1 CONFIGURATION UPDATE

### 7.1.1 Introduction

The configuration of the Avisaro 4.0 defines how the devices behave. Settings like baud rate, time and date, Internet access parameter, etc. are variable and can be defined by the user.

There are two ways to configure the Avisaro 4.0 devices:

1) Connect the device to a PC using a Micro-USB cable. On the PC, configuration software can be used to make all the settings via user-friendly drop-down menus. The software ("PC Companion") is provided by Avisaro free of charge.
2) The configuration can also be applied by USB stick. Once a valid configuration is made using the PC Companion software, a configuration file can be created. This configuration file is placed on a USB stick and automatically loaded by the device.

### 7.1.2 Via "PC Companion" Software

Configuration via the "PC Companion" software is the most user-friendly way to configure the Avisaro devices. Use this as your preferred method.

See paragraph "PC Companion Software" for details on where to get and how to operate the software.

Find the complete reference manual for the PC Companion Software here:

https://www.avisaro.de/files/Avisaro/40_Docu/Avisaro-PC-Companion-Manual.pdf

### 7.1.3 Via USB Stick

Firmware requirements: 2.66 or larger (2022/03/28 or newer)

To configure devices within the application or without the usage of a PC/Notebook, a USB stick with a configuration file can be used. This configuration file is generated using the PC Companion tool.

**Please note:** The PC Companion Tool needs a connected device to operate. Thus, one device 'on your desk' is needed to generate this update file.

**Please note:** It is important the firmware versions match. The device from which the configuration is extracted must have the same firmware as the device the configuration is applied to.

How is works:

1) Connect to the local Avisaro 4.0 device which contains the configuration to be extracted.
2) Use the "PC Companion" software and navigate to "Commands->Device Control"

3) Click on “Backup (BIN) to generate a binary copy of the configuration:




The generated file is usually named like “20220328 configuration” for better documentation.

4) Copy the configuration file on a USB Stick and **rename it to “avi40cnf.bin”** and insert the USB stick in the Avisaro 4.0 device.
5) … the update is performed and the Avisaro device reboots … this takes roughly 30sec to 1 minute
6) The **“avi40cnf.bin” file is deleted** from the USB stick once the configuration update was successful.

**Please note:** A firmware update and a configuration update can be done in one sequence. Thus, place both files on the same USB stick. The SET PC_Headline_DataEndp TO $'''%RootDir%\\Kapitel - Companion\\Kapitel PC Headline DataEnd.docx''' order is: first, the firmware update is performed, second, the configuration update is performed.

## 7.2 Firmware Update

### 7.2.1 Introduction

There are three ways to update the firmware of the Avisaro 4.0 family:

1. Via USB Stick
   If the Avisaro 4.0 product has a USB Host port, a new firmware can be uploaded using a USB stick. See details below.
2. Via PC Companion software
   If the Avisaro 4.0 product is connected to a PC via USB cable, the firmware can be updated using the PC companion software. See details below.
3. Via Remote Update
   For selected products, a remote firmware update via FTP server / Internet is provided.
   See paragraph “Remote Firmware Update” for details.

The latest firmware version can be found online: http://www.avisaro.de/de/40-Firmware.html

### 7.2.2 Via USB stick

Instructions:

- Download the latest version of the firmware from the link posted above
- Unpack the *.zip file to retrieve the “avi40up.bin” file
- Copy the file onto a USB stick in the root directory
- Power up the Avisaro data logger
- Insert the USB stick
    - After a few seconds, the LED flashes red (the firmware is loaded)
    - After about 30 seconds, the LED flashes white (critical update phase, to not interrupt)
    - The logger reboots and starts again to show a green LED
- The firmware update file is deleted from the USB stick when finished - this is to avoid accidentally a restart of the process.
- Done !

**Warning:**

- Ensure stable and sufficient power supply during this process. There is a risk that the device becomes unusable if there is a power failure during the process. Those broken devices needs to be send in to Avisaro for repair.

Background:

- The configuration remains - if not stated otherwise - the same. Thus, all settings stay the same after a firmware update

### 7.2.3 Via “PC Companion” Software

See paragraph “PC Companion Software” for details.

### 7.2.4 Via FTP server / internet

Avisaro Devices can be updated remotely. This is a powerful service feature. To enable, navigate to “Data Endpoints”->“CLoud setting” and activate “Remote firmware update”. Please refer to the document “PC Companion” for details, chapter “Data Endpoints-> Cloud Settings”.

The update procedure is as follows:

- Place the new firmware file - usually called “avi40up.bin” on the FTP server
- Rename the file into “avi40up.xin
- The data logger, if enabled, searches every hour the directory. If an update file is found, it is downloaded and executed automatically.

Important note:

- Make sure that the data logger has sufficient and stable power supply during the update procedure. If power fails, the device can be left non-operational and needs service attention.

(To be precise: the download is not critical, but when the update is executed, there is a window of 30 seconds which is sensitive to power failure)

Recommendations:

- It is highly recommended to create a different user pointing to a different subdirectory for each Avisaro Data logger. This way, a firmware update can be directed to each.

# 8 DECLARATIONS

## 8.1 EC/EU DECLARATION OF CONFORMITY

avisaro
industrial information technology

**EG/EU Konformitätserklärung**
*EC/EU Declaration of Conformity*

| | |
|---|---|
| Name des Herstellers<br>*Manufacturer Name* | **Avisaro AG**<br>**Grosser Kolonnenweg 18 E**<br>**30163 Hannover**<br>**Germany** |

erklärt in alleiniger Verantwortung, dass das Produkt
*declares in its sole responsibility, that the product*

| | |
|---|---|
| Bezeichnung des Produkts<br>*Description of Product* | **Datenlogger 4.0 „Sky“** |
| Type(n)<br>*Type(s)* | **Serie M4xxx** |

mit den Anforderungen der folgenden Richtlinien und Normen übereinstimmt.
*is in conformity with the requirements of the following directives and standards.*

| Richtlinie(n)<br>*Directive(s)* | Norm(en)<br>*Standard(s)* |
|---|---|
| Bis / *until* 2016-04-19:<br>2004/108/EG<br><br>Ab / *from* 2016-04-20:<br>2014/30/EU | EN 55022 : 2010<br>EN 55024 : 2010 |
| Sonstige Normen:<br>*Other normes:* | EN 60950-1 : 2006<br>EN 60529 + A1 2000 (Cube IP 66) |

Hannover, 08.03.2016
Ort, Datum
*Place, date*

M. Colsman
Matthias Colsman
Leitung Entwicklung
*Head of development*

# 9 CONTACT AND SUPPORT

Please contact Avisaro if there are any questions:

Avisaro AG
Grosser Kolonnenweg 18 E
30163 Hannover
Germany

Email: support@avisaro.com

End of this documentation